

# Breakdown/Outage Restoration Plan for Power Supply Distribution Network of TSECL

(In Hours)

Sl. No.	Supply Area	Licensee's Fuse Failure	Snapping of LT Line	Falling of Tree causing no damage to Pole/str.	Break down due to short circuit of LT Line	Breakdown of 11 KV Overhead Line	Distribution Transformer Failure	Failure of Service Main	Breakdown of LT line other than specified earlier
1	Urban	1	3	3	3	3	5	1	2
2	Semi-Urban	2	4	4	4	4	6	2	3
3	Rural	2	6	6	6	10	12	5	8
4	Remote	5	10	10	10	18	24	10	10

## **N.B:**

### **A.**

- i) Urban means all Municipal Councils & Nagar Panchayet Areas
- ii) Semi-urban means Kanchanpur, Manu, Gandacherra, Bishramganj, Khumulwng, Kalyanpur, Salema, Chailengta, all Block, Sub-Divisional & District Head Qtrs. not covered under Municipal Councils & Nagar Panchayet Areas etc.
- iii) Remote means Raishyabari, Vangmoon, Shermoon Tilla, Chamanu area etc.

### **B.**

- i) The above restoration time schedule does not cover massive damage such as severe break down of lines, snapping of conductors, uprooting of poles etc. for which separate work force will be deployed for early restoration and time schedule shall be as per TERC (Standard of Performance) 2004 Regulations as per Annexure – I.